

HSA-75/4+0

- Surge arresters type T2+T3 ensure the equipotential bonding and reduce switching, induced and residual overvoltage in LV power supply systems.
- The products consist of varistors with big discharge ability.
- Configurations 1+1 and 3+1 are additionally combined with a gas discharge tube which ensures zero leakage current through the PE conductor.
- Installed at the boundaries of LPZ 1 LPZ 3 into subsidiary switchboards and control panels.
- If the product contains two PE (or PEN) terminals, it must not be used as a PE (PEN) bridge.
- **M** indication specifies a type of construction with removable module.
- **S** indication specifies a version with remote monitoring.

Test class according to EN 61643-11:2012 (IEC 61643-11:2011) System Number of poles Rated operating AC voltage Maximum continuous operating voltage AC Maximum discharge current (8/20) Nominal discharge current for class II test (8/20) Open circuit voltage of the combination wave generator Total discharge current (8/20) L1+L2+L3+N->PE Voltage protection level at I _n	U _N U _C I _{max} I _n U _{OC} I _{Total} U _p U _p U _T	T2, T3 TN-S 4 60 V 75 V 40 kA 15 kA 6 kV 160 kA < 0.4 kV < 0.3 kV
Number of poles Rated operating AC voltage Maximum continuous operating voltage AC Maximum discharge current (8/20) Nominal discharge current for class II test (8/20) Open circuit voltage of the combination wave generator Total discharge current (8/20) L1+L2+L3+N->PE	$\begin{array}{c} U_C \\ I_{max} \\ I_n \\ U_{OC} \\ I_{Total} \\ U_p \\ U_p \end{array}$	4 60 V 75 V 40 kA 15 kA 6 kV 160 kA < 0.4 kV
Rated operating AC voltage Maximum continuous operating voltage AC Maximum discharge current (8/20) Nominal discharge current for class II test (8/20) Open circuit voltage of the combination wave generator Total discharge current (8/20) L1+L2+L3+N->PE	$\begin{array}{c} U_C \\ I_{max} \\ I_n \\ U_{OC} \\ I_{Total} \\ U_p \\ U_p \end{array}$	60 V 75 V 40 kA 15 kA 6 kV 160 kA < 0.4 kV
Maximum continuous operating voltage AC Maximum discharge current (8/20) Nominal discharge current for class II test (8/20) Open circuit voltage of the combination wave generator Total discharge current (8/20) L1+L2+L3+N->PE	$\begin{array}{c} U_C \\ I_{max} \\ I_n \\ U_{OC} \\ I_{Total} \\ U_p \\ U_p \end{array}$	75 V 40 kA 15 kA 6 kV 160 kA < 0.4 kV
Maximum discharge current (8/20) Nominal discharge current for class II test (8/20) Open circuit voltage of the combination wave generator Total discharge current (8/20) L1+L2+L3+N->PE	I _{max} I _n U _{OC} I _{Total} U _p	40 kA 15 kA 6 kV 160 kA < 0.4 kV
Nominal discharge current for class II test (8/20) Open circuit voltage of the combination wave generator Total discharge current (8/20) L1+L2+L3+N->PE	$\begin{array}{c} I_n \\ U_{OC} \\ I_{Total} \\ U_p \\ U_p \end{array}$	15 kA 6 kV 160 kA < 0.4 kV
Open circuit voltage of the combination wave generator Total discharge current (8/20) L1+L2+L3+N->PE	U _{OC} I _{Total} U _p U _p	6 kV 160 kA < 0.4 kV
Total discharge current (8/20) L1+L2+L3+N->PE	I _{Total} U _p U _p	160 kA < 0.4 kV
, ,	U_p U_p	< 0.4 kV
Voltage protection level at I _n	Up	
		< 0.3 kV
Voltage protection level at U _{OC}	U_{T}	
Temporary overvoltage test (TOV) for $t_T = 5 s$		91 V
Temporary overvoltage test (TOV) for $t_T = 120 \text{ min}$	U _T	104 V
Response time	t _A	< 25 ns
Maximal back-up fuse		160 A gL/gG
Residual current	I _{PE}	≤ 600 μA
Short-circuit current rating at maximum back-up fuse	I _{SCCR}	60 kA _{rms}
Lightning protection zone		LPZ 1-2, LPZ 2-3
Housing material		Polyamid PA6, UL94 V-0
Degree of protection		IP20
Operating temperature	Э	-40 ÷ 70 °C
Humidity range	RH	5 ÷ 95 %
Minimum cross-section of connected Cu conductors accord. to HD 60364-5-53:2022 (doesn't apply to "V" connection) for T2	S	2.5 mm² (L, N) 6 mm² (PE, PEN)
Clamp fastening range (solid conductor)		1.5 ÷ 25 mm ²
Clamp fastening range (stranded conductor)		1.5 ÷ 16 mm ²
Tightening moment		3 Nm
Installation		On DIN rail 35 mm
Modular width		4 TE




Туре		HSA-75/4+0
Operating position		Any
Product placement environment		Internal
Signalling at the device		Optic
Importance of local signaling		OK – clear target FAULT – red target
Remote signalling		No
Modular design		No
Lifetime		> 100 000 h
Designed according to standards		
Requirements and test methods for SPDs connected to low-voltage power systems		IEC 61643-11:2011
Safety of Flammability of Plastic Materials		UL 94
Application standards		
Protection against lightning		IEC 62305:2010
Selection and erection of electrical equipment – Switchgear and controlgear		HD 60364-5-53:2022
Selection and application principles for SPDs connected to low-voltage power systems		CLC/TS 61643-12:2009
Ordering, packaging and additional data		
Mass	m	340 g
Mass (including the packaging)	m	368 g
Packaging dimensions (H x W x D)		74 x 112 x 73 mm
Packaging value	V	0.61 dm ³
ETIM group		EG000021
ETIM class		EC000941
Customs tariff no.		85363010
EAN code		8590681114933
Art. number		24 506



The link in the QR code leads to the online presentation of the **HSA-75/4+0**. There, in addition to the always up-to-date data sheet, you will also find all diagrams and drawings, declarations of conformity, or 2D or 3D models and other necessary materials. For more information, visit **www.hakel.com**



Application wiring diagram (installation)



Internal diagram

