





## HSA-150/3+0 S

- Surge arresters type T2+T3 ensure the equipotential bonding and reduce switching, induced and residual overvoltage in LV power supply systems.
- The products consist of varistors with big discharge ability.
- Configurations 1+1 and 3+1 are additionally combined with a gas discharge tube which ensures zero leakage current through the PE conductor.





65.8

- Installed at the boundaries of LPZ 1 LPZ 3 into subsidiary switchboards and control panels.
- If the product contains two PE (or PEN) terminals, it must not be used as a PE (PEN) bridge.
- **M** indication specifies a type of construction with removable module.
- S indication specifies a version with remote monitoring.

Test class according to EN 61643-11:2012 (IEC 61643-11:2011)T2, T3SystemITN-CNumber of poles3Rated operating AC voltageU <sub>N</sub> 120 VMaximum continuous operating voltage ACU <sub>C</sub> 150 VMaximum discharge current (8/20)I <sub>max</sub> 40 kANominal discharge current for class II test (8/20)I <sub>n</sub> 15 kAOpen circuit voltage of the combination wave generatorU <sub>OC</sub> 6 kVTotal discharge current (8/20) L1+L2+L3->PENI <sub>total</sub> 120 kAVoltage protection level at I <sub>n</sub> U <sub>D</sub> <0.65 kVVoltage protection level at I <sub>n</sub> U <sub>D</sub> <0.5 kVTemporary overvoltage test (TOV) for t <sub>T</sub> = 5 sU <sub>T</sub> 182 VTemporary overvoltage test (TOV) for t <sub>T</sub> = 120 minU <sub>T</sub> 230 VResidual currentI <sub>PE</sub> <400 µAShort-circuit current rating at maximum back-up fuseI <sub>SCCR</sub> 60 kA <sub>ms</sub> Lightning protection zoneIILPZ 1-2, LPZ 2-3Housing materialIIP20Operating time protection9-40 ÷ 70 °C
Number of poles3Rated operating AC voltage $U_N$ 120 VMaximum continuous operating voltage AC $U_C$ 150 VMaximum discharge current (8/20) $I_{max}$ 40 kANominal discharge current (8/20) $I_n$ 15 kAOpen circuit voltage of the combination wave generator $U_{OC}$ 6 kVTotal discharge current (8/20) L1+L2+L3->PEN $I_{rotal}$ 120 kAVoltage protection level at $I_n$ $U_p$ < 0.65 kV
Rated operating AC voltageUN120 VMaximum continuous operating voltage ACUC150 VMaximum discharge current (8/20)Imax40 kANominal discharge current for class II test (8/20)In15 kAOpen circuit voltage of the combination wave generatorUOC6 kVTotal discharge current (8/20) L1+L2+L3->PENIrotal120 kAVoltage protection level at InUp<0.65 kV
Maximum continuous operating voltage ACU150 VMaximum discharge current (8/20) $I_{max}$ 40 kANominal discharge current for class II test (8/20) $I_n$ 15 kAOpen circuit voltage of the combination wave generator $U_{oc}$ 6 kVTotal discharge current (8/20) L1+L2+L3->PEN $I_{rotal}$ 120 kAVoltage protection level at $I_n$ $U_p$ < 0.65 kV
Maximum discharge current (8/20) $I_{max}$ 40 kANominal discharge current for class II test (8/20) $I_n$ 15 kAOpen circuit voltage of the combination wave generator $U_{OC}$ 6 kVTotal discharge current (8/20) L1+L2+L3->PEN $I_{Total}$ 120 kAVoltage protection level at $I_n$ $U_p$ < 0.65 kV
Nominal discharge current for class II test (8/20)I n15 kAOpen circuit voltage of the combination wave generatorU Occ6 kVTotal discharge current (8/20) L1+L2+L3->PENI Total120 kAVoltage protection level at I nU p< 0.65 kV
Open circuit voltage of the combination wave generator $U_{OC}$ $G_{KV}$ Total discharge current (8/20) L1+L2+L3->PEN $I_{Total}$ 120 kAVoltage protection level at $I_n$ $U_p$ < 0.65 kV
Total discharge current (8/20) L1+L2+L3->PENI TotalI Total120 kAVoltage protection level at I n $U_p$ < 0.65 kV
Voltage protection level at $I_n$ $U_p$ < 0.65 kVVoltage protection level at $U_{OC}$ $U_p$ < 0.5 kV
Voltage protection level at $U_{OC}$ $U_p$ < 0.5 kVTemporary overvoltage test (TOV) for $t_T = 5$ s $U_T$ 182 VTemporary overvoltage test (TOV) for $t_T = 120$ min $U_T$ 230 VResponse time $t_A$ <25 ns
Temporary overvoltage test (TOV) for $t_T = 5 s$ $U_T$ $182 V$ Temporary overvoltage test (TOV) for $t_T = 120 min$ $U_T$ $230 V$ Response time $U_T$ $230 V$ Maximal back-up fuse $t_A$ $<25 ns$ Maximal back-up fuse $160 A gL/gG$ Residual current $I_{PE}$ $<400 \mu A$ Short-circuit current rating at maximum back-up fuse $I_{SCCR}$ $60 kA_{rms}$ Lightning protection zone $I_C$ $LPZ 1-2, LPZ 2-3$ Housing material $V$ $Polyamid PA6, UL94 V-0$ Degree of protection $IP20$ $IP20$
Temporary overvoltage test (TOV) for $t_T = 120 \text{ min}$ $U_T$ $230 \text{ V}$ Response time $t_A$ $<25 \text{ ns}$ Maximal back-up fuse160 A gL/gGResidual current $I_{PE}$ $\leq 400 \mu A$ Short-circuit current rating at maximum back-up fuse $I_{SCCR}$ $60 \text{ kA}_{rms}$ Lightning protection zoneI $CCR$ $CPZ 1-2, LPZ 2-3$ Housing material $CPZ$ $Polyamid PA6, UL94 V-0$ Degree of protectionI $IP20$
Response time $t_A$ < 25 nsMaximal back-up fuse160 A gL/gGResidual current $I_{PE}$ $\leq 400  \mu A$ Short-circuit current rating at maximum back-up fuse $I_{SCCR}$ $60  kA_{rms}$ Lightning protection zoneI $LPZ 1-2, LPZ 2-3$ Housing materialPolyamid PA6, UL94 V-0Polyamid PA6, UL94 V-0Degree of protectionIIP20
Maximal back-up fuse160 A gL/gGResidual current $I_{PE}$ $\leq 400 \ \mu A$ Short-circuit current rating at maximum back-up fuse $I_{SCCR}$ $60 \ kA_{rms}$ Lightning protection zone $C$ $LPZ 1-2, LPZ 2-3$ Housing materialPolyamid PA6, UL94 V-0 $IP20$
Residual current $I_{PE}$ $\leq 400 \ \mu A$ Short-circuit current rating at maximum back-up fuse $I_{SCCR}$ $60 \ kA_{rms}$ Lightning protection zoneILPZ 1-2, LPZ 2-3Housing materialPolyamid PA6, UL94 V-0IP20
Short-circuit current rating at maximum back-up fuse I I   Lightning protection zone I 60 kArms   Housing material Polyamid PA6, UL94 V-0   Degree of protection IP20
Lightning protection zoneLPZ 1-2, LPZ 2-3Housing materialPolyamid PA6, UL94 V-0Degree of protectionIP20
Housing material Polyamid PA6, UL94 V-0   Degree of protection IP20
Degree of protection IP20
Operating temperature $P$ $40 \cdot 70 \circ C$
Humidity rangeRH5 ÷ 95 %
Minimum cross-section of connected Cu conductors accord. to HD 60364-5-53:2022   S   2.5 mm² (L, N)     (doesn't apply to "V" connection) for T2   6 mm² (PE, PEN)
Clamp fastening range (solid conductor) 1.5 ÷ 25 mm <sup>2</sup>
Clamp fastening range (stranded conductor) 1.5 ÷ 16 mm <sup>2</sup>
Tightening moment 3 Nm
Installation On DIN rail 35 mm
Modular width 3 TE

## Surge arresters T2+T3




Туре		HSA-150/3+0 S
Operating position		Any
Product placement environment		Internal
Signalling at the device		Optic
Importance of local signaling		OK – clear target FAULT – red target
Remote signalling		Yes
Potential free signal contact (S) (recommended cross-section of remote monitoring max. 1 $\mbox{mm}^2\mbox{)}$		AC: 250 V / 1.5 A, DC: 250 V / 0.1 A
Modular design		No
Lifetime		> 100 000 h
Designed according to standards		
Requirements and test methods for SPDs connected to low-voltage power systems		IEC 61643-11:2011
Safety of Flammability of Plastic Materials		UL 94
Application standards		
Protection against lightning		IEC 62305:2010
Selection and erection of electrical equipment - Switchgear and controlgear		HD 60364-5-53:2022
Selection and application principles for SPDs connected to low-voltage power systems		CLC/TS 61643-12:2009
Ordering, packaging and additional data		
Mass	m	294 g
Mass (including the packaging)	m	318 g
Packaging dimensions (H x W x D)		60 x 113 x 73 mm
Packaging value	V	0.5 dm <sup>3</sup>
ETIM group		EG000021
ETIM class		EC000941
Customs tariff no.		85363010
EAN code		8590681115213
Art. number		24 542



**The link in the QR code** leads to the online presentation of the **HSA-150/3+0 S**. There, in addition to the always up-to-date data sheet, you will also find all diagrams and drawings, declarations of conformity, or 2D or 3D models and other necessary materials. For more information, visit **www.hakel.com** 



## Application wiring diagram (installation)



Internal diagram

